



CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005



Job No.: CTCE/BBMP/W.No.15/KRIDL/CUBE/2014-15



13.08.2014

TEST REPORT ON CONCRETE CUBES

Client : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Technical Manager, KRIDL, Bangalore.

Name of the work : Construction of Primary School Building in Dasarahalli Old Village Ward No.15, BBMP, Bangalore.

Reference : BBMP/AEE/TDSD/PR/15/2014-15

Sample ID : Reinforced Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm²

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M₂₀

Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm ²)
1	16.07.2014	13.08.2014	8.135	475.5	21.13
2	16.07.2014	13.08.2014	8.269	492.3	21.88
3	16.07.2014	13.08.2014	8.325	512.3	22.77

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.



Quality

Signature
ಶ್ರೀಮತಿ. ವಿದ್ಯಾ-ವರ್ಧಿನಿ
ಪ್ರಾ.ಪಂ.ಪ. ಕಾರ್ಯದರ್ಶಿ, ಬೆಂಗಳೂರು

Signature
M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.

Tele Fax : 23223227, Website : www.civiltechconsultants.com

E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com



CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005



Job No.: CTCE/BBMP/W.No.15/KRIDL/CUBE/2014-15



18.08.2014

TEST REPORT ON CONCRETE CUBES

Client : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Technical Manager, KRIDL, Bangalore.

Name of the work : Construction of Primary School Building in Dasarahalli Old Village Ward No.15, BBMP, Bangalore.

Reference : BBMP/AEE/TDSD/PR/15/2014-15

Sample ID : Reinforced Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm²

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M₂₀

Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm ²)
1	21.07.2014	18.08.2014	8.122	478.6	21.27
2	21.07.2014	18.08.2014	8.298	502.2	22.32
3	21.07.2014	18.08.2014	8.318	516.3	22.95

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

[Signature]

[Signature]
 ಮುಖ್ಯ ನಿರ್ದೇಶಕರ ಅಧಿಕಾರವು
 ಬಿ.ಎಸ್.ಎಸ್. ಸರ್ಕಾರಿ-ಶಾಲೆ
 ಮುಖ್ಯನಿರ್ದೇಶಕರ, ಬಿ.ಎಸ್.ಎಸ್.
 ಬೆಂಗಳೂರು

[Signature]
M/s. Civil-Tech Consultants & Engineers
 # 23/14, 7th Cross, 3rd Stage,
 4th Block, Shakthiganapathinagara,
 Basaveshwaranagar,
 Bangalore-560079.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.

Tele Fax : 23223227, Website : www.civiltechconsultants.com

E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com



CIVIL-TECH CONSULTANTS AND ENGINEERS


Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005



Job No.: CTCE/BBMP/W.No.15/KRIDL/CUBE/2014-15



21.08.2014

TEST REPORT ON CONCRETE CUBES

Client : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Technical Manager, KRIDL, Bangalore.

Name of the work : Construction of Primary School Building in Dasarahalli Old Village Ward No.15, BBMP, Bangalore.

Reference : BBMP/AEE/TDSD/PR/15/2014-15

Sample ID : Reinforced Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm²

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M₂₀

Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm ²)
1	24.07.2014	21.08.2014	8.118	476.8	21.19
2	24.07.2014	21.08.2014	8.265	490.2	21.79
3	24.07.2014	21.08.2014	8.398	510.6	22.69

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.

Tele Fax : 23223227, Website : www.civiltechconsultants.com

E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com



CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005



Job No.: CTCE/BBMP/W.No.15/KRIDL/CUBE/2014-15

03.09.2014



TEST REPORT ON CONCRETE CUBES

Client : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.
Agency : Technical Manager, KRIDL, Bangalore.
Name of the work : Construction of Primary School Building in Dasarahalli Old Village Ward No.15, BBMP, Bangalore.
Reference : BBMP/AEE/TDSD/PR/15/2014-15
Sample ID : RCC Roof Slab Concrete - Ground Floor
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 mm²
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : M₂₀
Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm ²)
1	06.08.2014	03.09.2014	8.258	478.6	21.27
2	06.08.2014	03.09.2014	8.335	510.2	22.68
3	06.08.2014	03.09.2014	8.425	522.6	23.23

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

ಶ್ರೀಮತಿ ಕಾರ್ತಿಕಾ ಶರಣ್
ಪಿ.ದಾಸರಾಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಕೋಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakhiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakhiganapathinagara, Basaveshwaranagar, Bangalore-79.

Tele Fax : 23223227, Website : www.civiltechconsultants.com

E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com



CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005



Job No.: CTCE/BBMP/W.No.15/KRIDL/CUBE/2014-15



10.09.2014

TEST REPORT ON CONCRETE CUBES

Client : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.
Agency : Technical Manager, KRIDL, Bangalore.
Name of the work : Construction of Primary School Building in Dasarahalli Old Village Ward No.15, BBMP, Bangalore.
Reference : BBMP/AEE/TDSD/PR/15/2014-15
Sample ID : Reinforced Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 mm²
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : M₂₀
Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm ²)
1	13.08.2014	10.09.2014	8.258	478.6	21.27
2	13.08.2014	10.09.2014	8.335	510.2	22.68
3	13.08.2014	10.09.2014	8.425	522.6	23.23

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

[Signature]

[Signature]
ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ದಾಸರಹಳ್ಳಿ, ಉಪ-ವಿಭಾಗ
ಬಾಗಲಕೋಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

[Signature]
M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.

Tele Fax : 23223227, Website : www.civiltechconsultants.com

E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com



CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005



Job No.: CTCE/BBMP/W.No.15/KRIDL/CUBE/2014-15

16.09.2014



TEST REPORT ON CONCRETE CUBES

Client : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.
Agency : Technical Manager, KRIDL, Bangalore.
Name of the work : Construction of Primary School Building in Dasarahalli Old Village Ward No.15, BBMP, Bangalore.
Reference : BBMP/AEE/TDSD/PR/15/2014-15
Sample ID : Reinforced Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 mm²
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : M₂₀
Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm ²)
1	19.08.2014	16.09.2014	8.110	482.2	21.43
2	19.08.2014	16.09.2014	8.258	502.3	22.32
3	19.08.2014	16.09.2014	8.379	516.3	22.95

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

ಪ್ರಾಂಶುಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ದಾಸರಾಹಳ್ಳಿ, ಉಪ-ವಿಭಾಗ
ಬಾಂಟ್ವಾಳ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shaktiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakti Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.

Tele Fax : 23223227, Website : www.civiltechconsultants.com

E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com



CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005



Job No.: CTCE/BBMP/W.No.15/KRIDL/CUBE/2014-15

26.09.2014



TEST REPORT ON CONCRETE CUBES

Client : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Technical Manager, KRIDL, Bangalore.

Name of the work : Construction of Primary School Building in Dasarahalli Old Village Ward No.15, BBMP, Bangalore.

Reference : BBMP/AEE/TDSD/PR/15/2014-15

Sample ID : RCC Roof Slab Concrete - First Floor

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm²

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M₂₀

Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm ²)
1	29.08.2014	26.09.2014	8.125	474.6	21.09
2	29.08.2014	26.09.2014	8.235	488.3	21.70
3	29.08.2014	26.09.2014	8.347	510.6	22.69

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

Handwritten signature and stamp of the laboratory.

M/s. Civil-Tech Consultants & Engineers
 # 23/14, 7th Cross, 3rd Stage,
 4th Block, Shakthi Ganapathinagara,
 Basaveshwaranagar,
 Bangalore-560079.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.

Tele Fax : 23223227, Website : www.civiltechconsultants.com

E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com



CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005



Job No.: CTCE/BBMP/W.No.15/KRIDL/CUBE/2014-15



03.10.2014

TEST REPORT ON CONCRETE CUBES

Client : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Technical Manager, KRIDL, Bangalore.

Name of the work : Construction of Primary School Building in Dasarahalli Old Village Ward No.15, BBMP, Bangalore.

Reference : BBMP/AEE/TDSD/PR/15/2014-15

Sample ID : Reinforced Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm²

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M₂₀

Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm ²)
1	05.09.2014	03.10.2014	8.129	478.3	21.26
2	05.09.2014	03.10.2014	8.286	502.5	22.33
3	05.09.2014	03.10.2014	8.345	519.6	23.09

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

ಶಾಕ್ತಿ ಗಣಪತಿ ನಗರ
ಬಸವೇಶ್ವರನಗರ, ಬೆಂಗಳೂರು
03.10.2014

M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.

Tele Fax : 23223227, Website : www.civiltechconsultants.com

E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com



CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005



Job No.: CTCE/BBMP/W.No.15/KRIDL/CUBE/2014-15

13.10.2014



TEST REPORT ON CONCRETE CUBES

Client : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.
Agency : Technical Manager, KRIDL, Bangalore.
Name of the work : Construction of Primary School Building in Dasarahalli Old Village Ward No.15, BBMP, Bangalore.
Reference : BBMP/AEE/TDSD/PR/15/2014-15
Sample ID : Reinforced Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 mm²
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : M₂₀
Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm ²)
1	15.09.2014	13.10.2014	8.199	480.5	21.36
2	15.09.2014	13.10.2014	8.230	516.8	22.97
3	15.09.2014	13.10.2014	8.318	526.3	23.39

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

Signature

Signature
ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ.ದಾಸರಾಹಳ್ಳಿ, ಉಪ-ವಿಭಾಗ
ಜಾಲೇಗುಡಿ, ಬಿಜಿಎಂಪಿ
ಬೆಂಗಳೂರು

Signature
M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.

Tele Fax : 23223227, Website : www.civiltechconsultants.com

E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com



CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005



Job No.: CTCE/BBMP/W.No.15/KRIDL/CUBE/2014-15

22.10.2014



TEST REPORT ON CONCRETE CUBES

Client : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Technical Manager, KRIDL, Bangalore.

Name of the work : Construction of Primary School Building in Dasarahalli Old Village Ward No.15, BBMP, Bangalore.

Reference : BBMP/AEE/TDSD/PR/15/2014-15

Sample ID : RCC Roof Slab Concrete - Second Floor

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm²

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M₂₀

Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm ²)
1	24.09.2014	22.10.2014	8.098	476.3	21.17
2	24.09.2014	22.10.2014	8.180	501.6	22.29
3	24.09.2014	22.10.2014	8.280	520.1	23.12

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

Signature

Signature
ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಪಿ.ವಾಸುದೇವ್, ಕಾರ್ಯ-ವಿಭಾಗ
ಬಾಸವೇಶ್ವರನಗರ, ಬೆಂಗಳೂರು
ಬೆಂಗಳೂರು

M/s. Civil-Tech Consultants & Engineers

23/14, 7th Cross, 3rd Stage,
4th Block, Shakti Ganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakti Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.

Tele Fax : 23223227, Website : www.civiltechconsultants.com

E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com



CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005



Job No.: CTCE/BBMP/W.No.15/KRIDL/CUBE/2014-15



25.10.2014

TEST REPORT ON CONCRETE CUBES

Client : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.

Agency : Technical Manager, KRIDL, Bangalore.

Name of the work : Construction of Primary School Building in Dasarahalli Old Village Ward No.15, BBMP, Bangalore.

Reference : BBMP/AEE/TDSD/PR/15/2014-15

Sample ID : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm²

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M₁₅

Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm ²)
1	27.09.2014	25.10.2014	8.135	352.6	15.67
2	27.09.2014	25.10.2014	8.288	365.6	16.25
3	27.09.2014	25.10.2014	8.335	375.3	16.68

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.



M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthi Ganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

ಸಹಾಯಕ ನಿರ್ಮಾಪಕ ಅಧೀನಪಡೆ
ಪಿ.ವಾಸುದೇವ, ಕಾರ್ಪೊರೇಟ್
ಮಾಲೀಕರಾಗಿ, ದಿವಾಂಸ
ಬೆಂಗಳೂರು

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.

Tele Fax : 23223227, Website : www.civiltechconsultants.com

E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com